

(105) 21/03/2023
THE KOLKATA MUNICIPAL CORPORATION
WATER SUPPLY DEPARTMENT

SAVE WATER SAVE LIFE

SANCTION ORDER

SAVE WATER SAVE LIFE

(Sanction/Permission for private water supply connection/or
Other works under provisions of sections
i) 258 read with sec. 558
ii) 254 read with sec. 260
iii) 235, 236, 239 read with sec. 260 of CMC Act, 1980)

Building Case No.: 2022100251 Date: 01/11/2022
Building Plan Sanction No.: 2022100205 Date: 18/01/2023
Borough No.: 10 Ward No.: 100 Assessee No.: 211000601516
Premises No. & Street Name: 23J NAKTALA ROAD
Owner Name: BIPLAB KUMAR DAS,
Name of KMC Licensed Plumber: KHOKAN LASKAR
Address of Plumber: 106, H. L. SARKAR ROAD 3, arunachal roynagar bansdronei 700070
Purpose: CONSTRUCTION NEW

Budget Code	Description	Amount
4231/211	Deposit money for water connection - 4231/211	0
4231/212	Road opening fees - 4231/212	356
4231/231	Extra road restoration - 4231/231	4381
4210/221	Annual fees for domestic purpose water supply - 4210/221	0
4210/262	Sale of water for non domestic purpose (ICI) - 4210/262	0
4210/299	Miscellaneous - 4210/299	374
4231/211	Fees for water connection - 4231/211	10000

Total Amount: 15111 Receipt No.: E/07/2022/5625 Date: 17/01/2023

Mode of Payment: Online

Details of Water Fittings:

Stop Cock Size: 25 Service Pipe Size: 25, 15 Water Tap Size: 15 Ferrule Size: 20

Please arrange for ferrule punching.
Road Opening Date: From 22.3.23 to 31.3.23

Note:

1) The above demand amount excludes physical execution of the work through KMC licensed plumber involving material, manpower & tools & plant cost.

2) Owners of the premises shall have to maintain all water fittings to prevent stagnation due to leakage & drain off water once a week from underground & overhead reservoirs and covered properly with well fitted lids for safeguard against contamination and mosquito breeding. Non-compliance may lead to cut off water connection u/s 275(b) of CMC Act, 1980 and will be treated as offence u/s 496 of the CMC Act. Ball cock is to be installed at underground reservoir to save water. It is also encouraged to install automatic pump tripping arrangement to avoid overflow from overhead reservoir.

As this is a computer generated document, it does not require actual signature.

Assistant Engineer (W.S.)

Executive Engineer (W.S.)