

(47) 12/05/2023

THE KOLKATA MUNICIPAL CORPORATION
WATER SUPPLY DEPARTMENT

~~SAVE WATER SAVE LIFE~~

SANCTION ORDER

~~SAVE WATER SAVE LIFE~~

(Sanction/Permission for private water supply connection/or
other works under provisions of sections
i) 258 read with sec. 558
ii) 254 read with sec. 260
iii) 235, 236, 239 read with sec. 260 of CMC Act, 1980)

Building Case No.: 2022120219

Date: 11/07/2022

Building Plan Sanction No.: 2023120032

Date: 20/04/2023

Borough No.: 12 Ward No.: 109 Assessee No.: 311090812997

Premises No. & Street Name: 1299 NAYABAD

Owner Name: SRI RAJARSHI NANDAN DAN,

Name of KMC Licensed Plumber: SRI RABINDRA NATH MUKHERJEE

Address of Plumber: VIVEKNAGAR CAL-75 700075

Purpose: CONSTRUCTION

NEW

Budget Code	Description	Amount
4231/211	Deposit money for water connection - 4231/211	0
4231/212	Road opening fees - 4231/212	350
4231/231	Extra road restoration - 4231/231	10903
4210/221	Annual fees for domestic purpose water supply - 4210/221	0
4210/262	Sale of water for non domestic purpose (ICI) - 4210/262	0
4210/299	Miscellaneous - 4210/299	374
4231/211	Fees for water connection - 4231/211	20000

Total Amount: 31633

Receipt No.: E/07/2023/589

Date: 17/04/2023

Mode of Payment: Online

Details of Water Fittings:

Stop Cock Size: 25	Service Pipe Size: 25	Water Tap Size: 12.7	Ferrule Size: 20
--------------------	-----------------------	----------------------	------------------

Road Opening Date: From 15/05/2023 to 16/05/2023

Note:

- 1) The above demand amount excludes physical execution of the work through KMC licensed plumber involving material, manpower & tools & plant cost.
- 2) Owners of the premises shall have to maintain all water fittings to prevent stagnation due to leakage & drain off water once a week from underground & overhead reservoirs and covered properly with well fitted lids for safeguard against contamination and mosquito breeding. Non-compliance may lead to cut off water connection u/s 275(b) of CMC Act, 1980 and will be treated as offence u/s 496 of the CMC Act. Ball cock is to be installed at underground reservoir to save water. It is also encouraged to install automatic pump tripping arrangement to avoid overflow from overhead reservoir.

** As this is a ~~PRINTED~~ generated document, it does not require actual signature **

Water Supply Br. XII
Assistant Engineer (W.S.)
The Kol. Mpl. Corporation

Executive Engineer (W.S.)