

**APPROVAL FORM
GOVERNMENT OF WEST BENGAL
DIRECTORATE OF ELECTRICITY
11,N.S. ROAD, KOLKATA – 700 001**

NO. : **ADS-CEI/2025/00159**

Dated : **04/09/2025**

From :: The CEI / Joint CEI / DYCEI / EI, Govt. of W.B.

To :: M/S **EPOCH GREENFIELDS PARKS DEVELOPMENT LTD**
Vanya Awas , Lataguri , Jharmatiali, Jalpaiguri, JALPAIGURI
Pin: 735219

Sub: No objection for installation of KVA, KV, 3Ph, 50C/S A.C Captive Generator/ Standby D.G.Set as per following details

S. No.	Maker Name	Serial No	KVA / KW rating*
1.	LEROY SOMER	LCS3H24K3595	160
2.	MECCALTE	P318470	250

at your premises addressed to **Vanya Awas , Lataguri , Jharmatiali, Jalpaiguri, JALPAIGURI, Pin : 735219**

Ref: Your Online Application no. **ADS-CEI/2025/00159** dated: **01/09/2025**

Sir /Ms **EPOCH GREENFIELDS PARKS DEVELOPMENT LTD,**

This is to confirm an inspection of the above electrical installation carried out by this office on **04/09/2025** and to state that the same was found generally in order during the said inspection. There is no objection under Regulations no. 34&/45 of the Central Electricity Authority (Measures relating to Safety and Electric supply) Regulations, 2023 to run the above set for your own power requirement subject to the conditions that—

1. You shall have to obtain No Objection Certificate from the Pollution Control Board, West Bengal and other statutory authorities as applicable.
2. The set is to be registered in the Directorate of Electricity Duty vide Rule 9D of Bengal Electricity Duty (Amendment) Rules, 1970.
3. The above Captive Generator/D.G Set should not be run in parallel with the supply of M/SWBSEDCL/ CESC Ltd without their written consent.



Yours faithfully,

**CEI / Joint CEI / DYCEI / EI,
West Bengal**