



Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186218700661

Date: 30-05-2022

**From:**  
Director  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

**To: A. TALUKDAR & CO. FERTILISERS PVT. LTD.**  
84/1A, TOPSIA ROAD (SOUTH), KOLKATA - 700 046

**Sub: Revised Fire Safety Recommendation for proposed Revised Fire Safety Recommendation for B+G+XI storied building under group of Residential Building in the favour of "A. Talukdar & Co. (Fertilisers) Pvt. Ltd." at the premises no. 17, Pagladanga Road, Ward no. 57, Borough VII, P.S.- Pragati Maidan (formerly Tiljala), Kolkata – 700105.**

This is in reference to your application no. 0125188228700083 dated 26-04-2022 regarding the Revised Fire Safety Recommendation for proposed Revised Fire Safety Recommendation for B+G+XI storied building under group of Residential Building in the favour of "A. Talukdar & Co. (Fertilisers) Pvt. Ltd." at the premises no. 17, Pagladanga Road, Ward no. 57, Borough VII, P.S.- Pragati Maidan (formerly Tiljala), Kolkata – 700105.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favor of the aforesaid building subject to the compliance of the following fire safety measure.

**Recommendation:**

The plan submitted by you was scrutinized and marked as found necessary from Fire safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation :-

Fire Safety Recommendation shall remain same as issued vide AIN No. 0125186218700661 Dated – 31.07.2021 and strictly maintained in addition to the following :

Basement :

1. Smoke/Heat detector shall have to be provided at the Basement.

Director  
West Bengal Fire & Emergency Services

Memo No.:FSR/0125186218700661