



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Date: 22-04-2023

Memo no.:FSR/0125186218700168

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: BIKASH KUMAR ROY
10A Ekdalia Place, Kolkata 700019

Sub: Fire Safety Certificate in respect of one G+5 storied residential building situated at premises no. 6/3, Anil Maitra Road, P.S.- Gariahat, Ward No.- 68, Borough- VIII, Kolkata- 700019.

This is in reference to your application no. 0125189238700113 dated 21-02-2023 regarding the Fire Safety Certificate in respect of one G+5 storied residential building situated at premises no. 6/3, Anil Maitra Road, P.S.- Gariahat, Ward No.- 68, Borough- VIII, Kolkata- 700019.


The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.The interior finish decoration of building shall be made with low flame spread material confirming I.S. specification.
- 2.To eliminate risk of Fire Hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
- 3.Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them.
- 4.The notice of Fire Fighting and Evacuation from the building shall be prepared prominently and displayed at all vulnerable places of the building.
- 5.Contact number of Emergency Departments shall be displayed.
- 6.The security staffs and residents shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire & Testing.
- 7.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the security personnel, employees and residents of the building.
- 8.First Aid Fire Fighting system shall be provided as per I.S. specification.
- 9.Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installations and equipments in the building to keep them in perfectly good working condition at all the times.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189238700113.

Page : 1

Powered By  For secure paperless solution
Please visit www.emsigner.com

10. Auto refilling of overhead water reservoir shall be maintained for all time.
11. Periodical flashing of water from the Yard Hydrants, Landing Valves, Hose Reel Hoses and sprinklers shall be made to maintain the efficient working performance.
12. Periodical testing of smoke detector and MCP shall be made to maintain the efficient working performance.
13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
14. Any deviation and failure in maintenance of the Fire Prevention and Fire Safety measures will be at the risk and liability of the Head of the Organization.
15. This Fire Safety Certificate is valid for three years and has to be renewed every interval of three years from the date of issue of this letter.

Signature Not Verified
Digitally signed by NIHAR
RANJAN ROY
Date: 2023.04.23 17:55:20 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189238700113.

Page : 2

Powered By  emSigner

For secure paperless solution
Please visit www.emsigner.com