



SCHEDULE OF FOUNDATION :-

FT. MKD	TYPE OF FOUNDATION	UNDER COLUMN	SIZE (MM)	DEPTH (MM)	REINFORCEMENT
F1	ISOLATED FOOTING	C1, C3, C4, C6, C7, C9, C10, C13, C15, C17 & C18.	1800X1800	200 TO 350 THK.	12 @ 125 C/C (B/W) AT BOTTOM
F2	ISOLATED FOOTING	C14 & C16.	2250X2250	200 TO 300 THK.	12 @ 140 C/C (B/W) AT BOTTOM
F3	ISOLATED FOOTING	C2, C5 & C12.	1600X2000	200 TO 300 THK.	12 @ 140 C/C (B/W) AT BOTTOM
F4	ISOLATED FOOTING	C8 & C11.	1600X3200	200 TO 300 THK.	12 @ 140 C/C (B/W) AT BOTTOM
F5	ISOLATED FOOTING	LIFTWELL	2500X2150	200 TO 350 THK.	12 @ 140 C/C (B/W) AT TOP & BOTTOM

SCHEDULE OF R.C.C. COLUMN :-

GR. MKD.	COLUMN MARKED	REINFORCEMENT UPTO 2ND FLOOR	REINFORCEMENT BEYOND THAT	REMARKS
GR-I	C5, C8, C11 & C14.	10-16 @ 200 C/C 8 @ TIES @ 200 C/C	6-16 @ 4-12 @ 200 C/C 8 @ TIES @ 200 C/C	
GR-II	C2, C3, C6, C7, C9, C10, C12 & C15.	8-16 @ 200 C/C 8 @ TIES @ 200 C/C	4-16 @ 4-12 @ 200 C/C 8 @ TIES @ 200 C/C	
GR-III	C1, C4, C13, C16, C17 & C18.	6-16 @ 200 C/C 8 @ TIES @ 200 C/C	4-16 @ 2-12 @ 200 C/C 8 @ TIES @ 200 C/C	

SCHEDULE OF SLABS :-

SLAB MKD.	THICKNESS	REINFORCEMENT	REMARKS
S1	110 MM	8 T @ 150 C/C BOTHWAYS AT BOTTOM 8 T @ 150 C/C EXTRA TOP OVER SUPPORT 8 T @ 200 C/C FOR BINDER	
S2	140 MM	8 T @ 150 C/C BOTHWAYS AT TOP & BOTTOM	
S3	200 MM	10 T @ 150 C/C BOTHWAYS AT TOP & BOTTOM	

