



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.: Medinipur, P.S.: Kotwali, Pin:- 721101

Memo No.: FSR/211862406300002139

Date : 10-07-2024

From :
Divisional Fire Officer
Paschim Medinipur Division
West Bengal Fire & Emergency Services

To :
1) Sk. Anwar Hussain, 2) Sri Atul Kumar Dubey, 3) Sri Pijush Agarwal, 4) Sri Arindam Maity In Favour Of " M/s
Iconic Construction"
Mouza-Rangamati, J.L. No.-150, L.R. Plot no.-748(P), Holding No.-378, P.S. - Medinipur, Dist - Paschim Medinipur,

Sub: Fire Safety Recommendation for Proposed Construction of G+V storied Residential Apartment under group
Residential Building in favour of M/S ICONIC CONSTRUCTION at Mouza- Rangamati, J.L. No.-150, L.R. Plot No.-
748(Part), Holding No.- 378, P.S.- Medinipur, Dist.- Paschim Medinipur, PIN- 721102, Under Midnapore
Municipality..

This is in reference to your AIN 211862406300002139 dated 04-Jun-2024 regarding Fire Safety Recommendation for
Proposed Construction of G+V storied Residential Apartment under group Residential Building in favour of M/S ICONIC
CONSTRUCTION at Mouza- Rangamati, J.L. No.-150, L.R. Plot No.- 748(Part), Holding No.- 378, P.S.- Medinipur, Dist.-
Paschim Medinipur, PIN- 721102, Under Midnapore Municipality.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In
returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the
aforesaid building for compliance of the following fire safety measure.

Recommendation :

A. CONSTRUCTION:

1. The whole construction of the building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipality Body.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. Provision of ventilation at the crown of the central core-duct of the building shall be provided.
4. Arrangement shall have to be made for sealing all the vertical and horizontal ducts by the materials of



adequate fire resisting capacity.

B. OPEN SPACE AND APPROACH:

1. The open spaces surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire Appliances with turning facility.
2. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting 45M.T.
3. The width and height of the access gate into the premises shall not be less than 5 mts. and 4.5 mts. respecting the abutting road.
4. Drive way should be free from any type of obstruction. No parking will be allowed on the drive way.
5. All the Passage way should be kept clear for free access.

C. STAIRCASE:

1. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having Fire Resisting capacity not less than 4 hours.
2. The staircase of the building shall have permanent vents at the top and openable sashes at each floor level in the external walls of the building.
3. The width of the staircase shall be made as marked in the plan. Corridors and the exit doors shall conform the relevant Building Rules with up to date amendment.
4. All the staircase shall be extended up to terrace of the building and shall be negotiated to each floor.

D. LIFT:

1. The walls of the lift enclosure shall be at least two hours Fire Resisting type.
2. Collapsible gate shall not be permitted.

E. FIRE FIGHTING WATER:

Overhead water reservoir capacity of 25,000 ltrs. exclusively for firefighting purpose with replenishing arrangements @ 1000 ltrs/min. preferably from two different sources of water supply shall be provided. The water reservoirs shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

F. HYDRANT SYSTEM:

1. The building shall be provided with Down comer of 100 mm. internal diameter pipe line with provision of landing valves at the staircase landings/half landings at the rate of one such riser for 1000 sqm. of floor area. The system shall be so designed that shall be kept charged with water all the time in auto mode with providing the one electric pump with the capacity 900 LPM & one stand by pump have same capacity as stand by pump of pressure and capable to discharge 900lt. /min. at the ground level outlet and at the top most outlet. In both cases the running pressure shall not be less than 3.5kgs/sq.cm. All other requirements shall conform I.S. 3844-1989.
2. Provision for Hose Reel in conjunction with down comer shall be made at each floor level and conforming the relevant I.S. Specifications.
3. One number of Two-way Fire Service Inlet shall be installed inside the building entry premises in accordance with relevant I.S. specifications.

G SPRINKLER INSTALLATION:

The automatic sprinkler installation shall be provided in entire Car parking area of the building as per I.S. 9972. Alarm Gong to be incorporated along with the sprinkler system.

H. Alternative Power Supply:

Arrangement shall have to be made to supply power with the help of a generator to operate at least the fire pump, fire alarm system and also for illumination in case of normal power failure.

I. ELECTRICAL INSTALLATION AND DISTRIBUTION:

1. The electrical installation including Transformers, Switch Gear, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in I.S. specification 1946-1982.
2. The vertical and horizontal electrical ducts shall be sealed at each floor level by fire resisting materials.
3. The electrical installation shall be adequately protected with CO2/D.C.P. Fire Extinguishers conforming I.S. specification.
4. Arrangement for alternative power supply shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Deep Tube-Well Pump, Fire Alarm System etc. and also for illuminating the Staircase, Corridors, Lobbies etc. and other places of assembly of the building in case of normal power failure.

J. DETECTION AND ALARM SYSTEM:



1. Manually operated Electrical Fire Alarm System with adequate numbers of break glass type call boxes fitted with Hooters along with Public Address System at each floor connecting with visual panel board shall be made in Control Room. The Control Room shall be located at entrance of ground floor of the building, other requirements of the system shall be made conforming I.S. 2189-1988.
2. Hooters will be sounded in such a manner so that an operation of a Detectors or Manual Call Point. Hooters will be sounded on the same floor and immediate alternate floor.
3. Public Address System linked between all floors and Control Room shall have to be established.

K. SMALL GEARS

Hose box, 15-meter length delivery hose, gunmetal short branch of half inch dia. one set at each pillar hydrants as IS:903-1993 specification should be installed.

L. FIRST AID FIRE FIGHTING SYSTEM:

First Aid Fire Fighting System First Aid firefighting arrangement in the style of placing suitable type of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190 - 1992.

M. AIR CONDITIONING SYSTEM (If any):

1. The A.H.U. shall be separated for each floor with the system. Air Ducts for individual floors.
 2. Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System.
 3. The system of auto shut down of A.H.U. shall be incorporated with the Auto Detection and Alarm System.
 4. The Air Handling Units room shall not be used for storage of any combustible First Aid Fire Fighting arrangement in the style of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.
- N. GENERAL RECOMMENDATIONS:**
1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
 2. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
 3. Floor numbers and directional sign of escape route shall be displayed prominently.
 4. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
 5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
 6. A crew of trained Fireman under the experienced Fire Officer shall be maintained round the clock for safety of the building.
 7. Mock Fire practice and Evacuation Drill shall be performed periodically with participation of all occupants of the building.
 8. A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

On compliance of all the above Life and Fire Safety Recommendation, the Director General, West Bengal Fire & Emergency Services shall be approved for necessary inspection and testing of all the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B.: Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.



Signature valid

Digitally Signed.
Name: Baran Kumar Chowdhury
Date: 10-Jun-2024 21:57:43
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services