



**WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LTD.**

**(A GOVERNMENT OF W.B ENTERPRISE)**

**OFFICE OF THE STATION MANAGER: BIDHANNAGAR CUSTOMER CARE CENTRE**

**BIDHANNAGAR, DURGAPUR**

**WBSEDCL**

Memo: BNCCC/NOC/590

DATE: 22/05/25

To,  
Vijay Agarwal,  
Gopinathpur, PS-Coke Oven,  
Durgapur-11, Paschim Bardhaman.

**Sub: NOC for providing electric connection.**

Ref: Your prayer for NOC, Rec. no.231, dated-21.05.2025.

Dear Sir/Madam,


In reference to the above application received at this office on dated 21.5.2025, NOC i.r.o your proposed project of Residential Apartment at R.S. Plot No. 1633 &, LR plot no. 2936, Mouza: Gopinathpur, P.S.-Coke Oven, Durgapur-11 may be given subject to the following:

1. Development of the infrastructure (i.e. installation of distribution transformer, drawal of LT and HT line, meter connection etc.) to serve the contractual load demand shall be carried out under the supervision of WBSEDCL. It may be presumed that, the consumer is ready to wait for the new electric connection, until the aforesaid infrastructure is developed and is capable to serve the demand load.
  2. Necessary way leave (as per clause no 3.2.1/c of notification 46 of WBERC) for installation of new transformer and other LT and HT network, must be arranged by the consumer.
  3. The entire LT and HT system and network will be the property of WBSEDCL.
  4. An agreement must be executed in the prescribed format annexed with the form. (Application form for the new electric connection in residential/commercial complex)
  5. The consumer must ensure minimum necessary safety clearance from the existing L&MV electrical lines.
- The mandatory clearance of any building from any existing L&MV overhead lines as per Electricity Act. 2003 is reproduced below:-

| Sl.No. | Mandatory clearance in Meter (feet)                                                                | L&MV (upto 11KV)      |
|--------|----------------------------------------------------------------------------------------------------|-----------------------|
| 1      | Vertical clearance of OH line from highest point of the building/structure (permanent/temporary)   | 3.7 Meter (12.5 feet) |
| 2      | Horizontal clearance of OH line from nearest point of the building/structure (permanent/temporary) | 1.2 Meter (4 feet)    |

This is for your kind information and necessary action please.

Thanking you,

  
STATION MANAGER  
BIDHANNAGAR CCC

WBSEDCL  
DE & STATION MANAGER  
BIDHANNAGAR, C.C.C  
W.B.S.E.D.C.L