

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D, Mirza Ghalib Street, Kolkata - 700 016.**

Memo. No. : WBFES / 7771 / 17 / Kol-RB/412/14 (412/14)

Date: 11.10.17

From : Divisional Fire Officer  
Fire Prevention Wing  
West Bengal Fire & Emergency Services.

To : The Authorized Signatory,  
Spring Dealcom Pvt. Ltd.,  
4C, Chaitan Sett Street,  
Kolkata-700 007.




Sub : Revised Fire Safety Recommendation for Proposed Construction of B+G+VII Storied Instead of B+G+V Storied Under Group Residential Building at the Premises No.- 80/1, Pathuriaghat Street, Ward No.-21, P.S.-Jorabagan, Kolkata-700 006.

This is in reference to your Letter No. Nil, Dated. 25.05.2017, Regarding Revised Fire Safety Recommendation for Proposed Construction of B+G+VII Storied Instead of B+G+V Storied Under Group Residential Building at the Premises No.- 80/1, Pathuriaghat Street, Ward No.-21, P.S.-Jorabagan, Kolkata-700 006.

The revised plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan, this office has approved Revised Plan Drawing in favour of the aforesaid building subject to the compliance of the Fire Safety Measure and the automatic Sprinkler installation shall be provided in basement, first floor & second floor area of the building as per I.S. 9972 and as Recommendation issued earlier vide this office memo no. WBFES/234/14/ Kol-RB/412/14 (412/14) Dated-09.04.14 remains same & shall strictly to be followed.

Enclose:

1. One set of plan.

  
Divisional Fire Officer  
Fire Prevention Wing  
West Bengal Fire & Emergency Services