## BIPLAB GHOSH

REGISTERED CIVIL ENGINEER & CONSULTANT OF BARUIPUR MUNICIPALITY, 24 PARGANAS(S).

REGISTRATION NO.- 021/BM/ENG./BLDG/24

CONT.-7278810650, E-MAIL-biplabghosh8220@gmail.com

## To Whom It May Concern

This is to declare and certify that the height of the Building Named "SHIVALAYA APARTMENT" at Beltola, Subuddhipur, Baruipur, Kol.-144, P.S.-Baruipur, W.B., India, is 14.46 Meters and has not crossed the threshold limit for mandatory WBFIRE Clearance, i.e. 14.50 Meters.

Although the PERMISSIBLE HEIGHT as mentioned in sanction plan is 15.4 Meters, the Developer is constructing till 14.46 meters only.

I, the undersigned has verified the same as a Technically Qualified professional and do hereby declare that the project named "SHIVALAYA APARTMENT" does not cross the threshold limit as per WBFIRE Rules.

I declare the above statement to be fully true and correct.

Bllwsh
BIPLAB GHOSH B.Tech (Civil)

Barwipur Municipality

LBS-I / Reg. No.-0.21/BM/ENG/BLDG/24

## **BIPLAB GHOSH**

REGISTRATION NO.- 021/BM/ENG./BLDG/24.