

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No. : WBFES/ 6395/07 /Kol.- I.T. Park /265/07 (269/07)

Date : 12/10/2007.

From : Director,
West Bengal Fire & Emergency Services.

To : Sri Goutam Sen Gupta,
Chief Operating Officer,
Kitchen Appliances India Ltd,
Sector-V, Block-BP, Salt Lake, Kol – 700 091.

Sub : Provisional N.O.C. for Proposed construction of B+LG+G+XXI storied I.T. Building at Premises No.-B.P.-1, sector-V, Salt Lake, Kolkata – 700 091.

Sir,

This is in reference to your letter dated 19.06.2007 regarding Provisional N.O.C. of Fire safety measure for Proposed construction of B+L.G+G+XXI storied I.T Building at Premises No - B.P.-1, sector-V, Salt Lake, Kolkata – 700 091

The plan submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing Provisional N.O.C. in favour of the aforesaid building subject to the compliance of the following fire measure.

Enclo. :

1. One set of plan.
2. Recommendation placed in this file.

Yours faithfully,


DIRECTOR

WEST BENGAL FIRE & EMERGENCY SERVICES

RECOMMENDATION

A. CONSTRUCTION:

1. Materials for rapid flame spread categories including untreated wood fibre board etc. shall be not use. The doors and windows preferably shall be made of metal.
2. The floor area exceeds 750m² shall be suitably compartmented having four hours fire resisting capacity. sprinkler system should be provided as per N.B.C. Part IV.
3. The interior finish decoration of the building shall be made with the materials with low flame spread and low smoke and toxic gas generating categories conforming I.S. Specification.
4. All principal staircases shall not be permitted from the Basement.
5. Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.
6. Fire rating test certificate of all interior finish decoration should be submitted to this office before taking occupancy.
7. Service Ducts and shafts should be enclosed by a wall of 2 hours and doors of one hour fire rating. All such ducts shall be properly sealed and Fire stopped at all floor levels.

B. OPEN SPACE & APPROACH:

1. The open space surrounding the building shall be kept clear open to sky and shall conform the relevant building rules as well as permit the easy accessibility and maneuverability of the Fire appliances with turning facility.
2. The approach road and roads surrounding the building shall be sufficiently strong to withstand the load of Fire Engine weighting up to 45 M.T.
3. The width and height of the entry gates to the promises shall not be less than 5m and 6m respectively abutting the road.
4. Drive way should be free of any type obstruction. No Parking will be allowed on the Drive Way.

C. STAIRCASE:

1. All principal staircases from Basement to top floor shall be pressurized as marked in the plan. A positive pressure of 25-30 pa. shall be maintained inside the staircases. Pressurization shall be maintained round the clock.
2. The staircases of the building shall be enclosed type. entire construction shall be made of brick / R.C.C type having Fire resisting capacity not less than 4 hours respectively marked in the plan.
3. All the staircases of the building shall be negotiable to each other in each floor without entering into any room and shall be extended upto respective terrace. The roof of the stair wall shall be 1M above the surrounding roof area.
4. The width of the staircases and corridors and travel distance of different categories of occupancies shall have to conform the relevant building rules.

5. Fire and Smoke doors at the entrances of all the Staircase enclosures at each floor level shall be provided. The F.C.D. shall be of at least one hour Fire resisting wire glass window fitted with self closing type open able in the direction of escape.

6. Considering the staircases are only means of evacuation, emergency lighting arrangement directional, exit, sign etc. shall be made conforming the relevant I.S. Code in this regards.

D. LIFT:

1. The walls of the lift enclosure of the building shall be at least two hours FIRE resisting type respectively marked in the plan with the event at top of area not less than $0.2m^2$.

2. The lifts of the building shall be designed at high speed "Fire Lift" and conspicuously indicated marked in the plan.

3. One of the lift car of the building shall be large enough to accommodate standard Ambulance Stretcher and Medical Attendants.

4. The Electric power shall be from separate supply mains in the Building and Cables run with in the Lift Shafts, Light and Fans in the Lift cars shall be operation from 24 Volts, supply on emergency in case of failure of normal power supply lift shall automatically trip over alternate power supply.

5. Arrangement shall be provided for extraction of smoke in all the lift shaft by incorporation smoke venting system designed to permit 30 Air changes per hour in case of Fire and shall be of such design as to operate on actuation of Sprinkler or Fire Alarm. In case of failure of normal electric supply. It shall automatically trip to alternate supply.

6. Exit doors of the lift lobby shall be through a self-closing smoke stop floor of 1 hour fire resistance

7. The speed of the fire lifts in the building shall be such that it can reach the top from the ground floor within 1 minute in visual indications of floor numbers shall incorporated in the lift cars

8. All other requirements shall conform the I.S. specifications including the communication facility in the lift cars connecting with the Fire Control Room of the building.

9. All Lifts & Lobbies from lower ground to top floor shall be pressurized as marked in the plan drawing. A positive pressure of 25-30 pa. shall be maintained inside the lift wall and lobby. Pressurization shall be maintained round the clock.

E. REFUGE AREA:

1. Refuge area is not less than $1.5sqm$. Shall be provided on the external wall with cantilever projection or other suitable means at above 24m & every alternate of 15m. levels of the building as shown in the drawings.

2. The refuge areas shall be of Fire resisting construction and protected with self - closing Fire and Smoke check door at the entrance from the corridors at staircase lobbies

3. The position of refuge areas shall be such so that they are negotiable by the Fire Service Ladder from the Ground.

BASEMENT AREA :

1. All The Basement areas shall be properly ventilated with aggregate cross sectional area of not less than 2.5% of the area spread evenly round the perimeter of the basement shall be provided in the form of grills.
2. Mechanical smoke venting arrangements shall be provided to all the basements conforming the I.S. Specification.
3. The exits from the basement shall be form open Air and from any points the travel distance shall not exceeds 18.5 M to reach any exit. Continuation of staircase from the basement to upper floor will not be allowed i.e. all staircases shall be segregated on the ground floor level
4. All the basement areas shall be protected with Auto Sprinkler System conforming to I.S. 3844-1989
5. The staircase of basement shall be of enclosed type having Fire resistance of not less than 4 hrs. and shall be situated at the periphery of the basement to be entered at ground level only from the open air and in such position that smoke from any Fire in the basement shall not obstruct any exit having the ground upper floor of the building.
6. Mechanical extractors shall have an alternative source of supply.
7. Mechanical extractors shall have an internal locking arrangement so that extracting shall continue to operate and supply fans shall stop automatically with the actuation of Fire Detectors.
8. Mechanical extractors shall be designed to permit 30 Air changes per hour in case of Fire or distress call

G. FIRE FIGHTING WATER:

1. Water exclusively for Fire Fighting operation shall be ensure minimum 5,00,000 lts all the times
2. The Fire water reservoir shall be have overflow arrangement with the domestic reservoir to avert stagnancy of water.
3. Provision of necessary manhole shall be made on the top of the reservoir as per specification.
4. Provision of replenishment at the rate of atleast 2000lts /min. from two separate source of water supplies shall be made.
5. The deep tube wells for the replenishment of the reservoir shall be incorporated with the auto starting facility with the actuation of auto detection and suppression arrangement of the premises and shall also be connected with dual power supply units.
6. Provision of placing Fire Appliances on the underground water reservoir to be made to draw water in case of emergency.

H. WATER LAYOUT SYSTEM:

a. Ring Main Hydrant System:

- i. 200 mm dia Ring Main water layout arrangement covering the entire premises of the project with provision of yard hydrants without door hose boxes, containing 2 lengths of 63mm delivery hose and short branch pipe shall be provided at all the strategic location and surrounding the building conforming I.S. 3844-1989 (upto date amendment).

- ii. The system shall be so designed that shall always be kept charged with water under pressure and capable to discharge min. 2850 ltrs./min. at the pressure 3.5kg/sq.cm. at any point.

b. Wet Riser & Hose Reels System:-

- i. The building shall be provided with Wet Riser and Hose Reel unit with provision of outlets in each floor at the staircases landings/half landings as per suitable at the rate of one such unit of Wet Riser and Hose Reel per 1000sq.m. of floor area.
- ii. The Wet Riser installation shall be made in reference to the height of the building in stage wise distributions.

From Ground Floor to 21st Floor 200mm. Dia. Twin Hydrant outlet.

- iii. Hose Reel Unit:- Provision of hose reel units on swiveling drums in conjunction with wet risers near each landing valves shall be made at each floor level of the building.
- iv. All other requirements of the water base Fire Protection System shall be made as per I. S. Specification 3844-1989 (with upto date amendment).

c. Automatic Sprinkler Installation :

- i. All floors of the building and basement area & warehouse shall be suitable protected by automatic Sprinkler installation conforming the grade as per I S Specification
- ii. The Sprinkler arrangement shall be laidout in Zonewise distribution preferably
Zone 1 –Basement.
Zone 2 –Ground floor to 7th floor.
Zone 3- 8th floor to 14th floor.
Zone 4- 15th floor to 21st Floor.

d. Water Projector Protection

The Electrical installations viz. transformer, HT, LT switch gear etc. shall be protected by high velocity water projector system as per suitability.

I. FIRE PUMP:

1. 2850 Lts. per min. giving a pressure not less than 3.0m/hr. The provision will be of multi-stage type suction and delivery size not less than 15cm. dia with low level riser upto seventh storied and high level riser delivery for upper floors upto 68M. a set of ball valves to supply the tank with at least 2850Lts per minute from the first pump. Alternatively a multistage, multi-outlet pump may be installed.
2. A standby Pump of equal capacity shall be provided on alternative source of supply. Another one pump. Provision of jockey Pump shall also have to be made to keep up the water based system under pressurized condition at all the time.

J. ELECTRICAL INSTALLATION & DISTRIBUTION SYSTEM:

1. Electrical distribution system of all the buildings shall be made in the form of concealed wiring or in heavy gauge M.S. conducted continuously bonded to earth cables shall be I.S. marked and preferably be of F.R.L.S. categories.
2. Electrical distribution System shall conform all the requirements laid in I.S. 1646-1982.

3. For every 230V. wiring above false ceiling 660 grade insulated cable shall be used Transformer Switch Gear H.T., L.T. and other electrical rooms shall be at the ground floor level the other electric rooms shall be at least 4hrs. fire resisting capacity adequate ventilation arrangement shall have to be made in all the rooms. Dry and explosion proof type transformer shall be installed.
4. All electrical installation viz. Transformer Switch Gear L.T., H.T. rooms shall be protected with both auto detection and suppression systems as per suitability.

K. AUTO DETECTION AND ALARM SYSTEM :

1. Auto Fire Alarm System which analogue addressable smoke heat detectors as per suitability shall be installed in all floor area of the building except Car parking area.
2. Addressable analogue manual call boxes incorporating with sounders shall be installed in all the floor area of the building in such a manner that maximum travel distance shall not be more than 30M. in order to reach any of the call point.
3. Both way Public address system shall be made available on all floors of the building. The system shall be connected to the main control room.
4. All the installation shall also satisfy the I.S. Specification 2189 (as amended) and the code of practice as laid down in N.B.C. pt. IV.

L. AIR CONDITIONING SYSTEM :

1. The A.H.U. shall be separated for each floor with the system Air Ducts for individual floors. In no way ducts shall be connected with the ducting system of other Floors.
2. Arrangement shall be provided for isolation at the strategic locations by incorporating auto dampers A.C system with operating facilities by auto detection systems besides the manual operating facility.
3. The system of auto shut down of A.H.U. shall be incorporated with the auto detection and alarm system installed in the building.
4. The A.H.U. shall be separated for each floor with the system of Air Ducts for individual floors.
5. Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System.
6. The system of auto shut down of AHU shall be incorporated with the auto detection and alarm system.
7. Escape route like staircases, common corridors, lift lobby etc. shall not be used as return air passage.
8. Wherever the ducts pass through Fire walls of floors, the opening arounding the ducts shall be sealed with Fire resisting materials such as asbestors rope vermiculite concrete etc.
9. The metallic ducts shall be used even for the return air instead of space above the false ceiling.
10. The materials used for insulating the duct system (inside or outside) shall be of non- combustible materials glass wool shall not be wrapped or secured by any materials of combustible nature.
11. Area more than 750 sq. m. on individual floor shall be segregated by a Fire wall and automatic fire dampers for isolation shall be provided.

12. Air duct services main floor area, corridors etc. shall not pass through the staircase enclosures.
13. The air handling units shall be separation for each floor, and air ducts for every floor shall be separated and in no way interconnected with the ducting of any other floor.
14. If the Air handling units serve more than 1(one) floor, the recommendation given above shall be complied with in addition to the conditions given below:-
 - a. Proper arrangements by way of automatic Fire dampers working on fusible links for isolating all ducting at every floor from the main riser shall be made.
 - b. When the automatic Fire alarm operates the respective air handling units of the air conditioning system shall automatically be switched off.
15. The vertical shaft for treated fresh air shall be of masonry construction
16. The air filters for air handling units shall be of non - combustible materials.
17. The air handling units room shall not be used for storage of any combustible materials.
18. Inspection panel shall be provided in the main trucking to facilitate the cleaning of ducts of accumulated dust and to obtain access for maintenance of fire dampers.
19. No combustible materials shall be fixed nearer than 15cm. to any duct unless such duct properly enclosed and protected with non combustible materials (glass wool or Spun wool with neoprene facing enclosed and wrapped with aluminum sheeting) at least 3.2m thick, and which would not readily conduct heat

M. FIRE DAMPER :

1. Fire damper shall be located in conditional air ducts and return air duct/passages at the following points.
 - a. At the fire separation wall.
 - b. There ducts/passage enter the central vertical shaft.
 - c. Where the ducts pass through floors.
 - d. At the inlet of supply Air Duct and the return air duct of each compartment on every floor.
2. The dampers shall operate automatically and shall simultaneously switch off the air handling fans. Manual operation facilities shall also be provided.
3. Automatic Fire Dampers shall be so arranged so as to close by gravity in the direction of Air movement and to remain rightly closed open operation of a fusible link.

N. FIRST AID FIRE FIGHTING SYSTEM :


1. First Aid Fire fighting arrangement in the style of placing suitable categories of portable Fire Extinguishers I.S. Bark Fire Buckets etc. on all floors and vulnerable locations of the premises shall be made in accordance with I.S. specification 2190-1992.
2. Special rescue equipment like Smoke Hood, self contained B.A. set portable lights at least two pairs (4sets) shall be made available in the main fire Control Room of the premises.

O. GENERAL RECOMMENDATIONS :

1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
2. Floor numbers and directional signs, showing the nearest exit refuge area, Fire Points etc. shall have photo luminescent signals at each floor of all blocks of building including shall be made available conforming the relevant I.S. Specification.
3. Provision of emergency illuminating exits shall be made at all floor levels of all blocks of building conforming the I.S. Specification.
4. If diesel oil is stored beyond the specified quantity license shall be accorded from the appropriate authority.
5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all time by authorized competent agency in this regard.
6. The occupants, employees and security staff shall know how to operate the First aid Fire Fighting equipments and systems installed in the building.
7. A crew of trained Fireman under the experienced Officer shall be maintained round the clock for safety of the building.
8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
9. Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

This shall be considered as provisional N.O.C. on compliance of all the aforesaid Fire and Life safety recommendations, The Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation. Final N.O.C. in favor of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B.: Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this provisional N.O.C. will be treated as cancelled.


DIRECTOR

West Bengal Fire & Emergency Services

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata – 700 016.**

Memo. No. : WBFES/ 1860/10 /Bidhan-IT/117/05(126/05)

Date : 9/4/10 .

From : **Director General,
West Bengal Fire & Emergency Services.**

To : Mr. Goutam Sengupta,
Videocon I.T.Park, Plot No.-I,
Block-BP, Sector-V, Salt Lake,
Kolkata.

Sub : Revised Provisional N.O.C. of G+IX storied Business building at Premises No.- Videocon I.T.Park, Plot No.-I, Block-BP, Sector-V, Salt Lake, Kolkata.

Sir,

This is in reference to your letter No. Nil dated 17.02.2010 regarding Revised Provisional N.O.C. of fire safety measure for proposed of G+IX storied Business building at Premises No.- Videocon I.T.Park, Plot No.-I, Block-BP, Sector-V, Salt Lake, Kolkata.

The plan drawing submitted by you were scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Provisional N.O.C. in favour of the aforesaid building subject to the compliance of the Fire Safety measure. The recommendation which was issued earlier vide this office memo No.- WBFES/9485/Bidhan-IT/117/05(126/05) dated 23.12.05 strictly to be followed.

Enclo. :

1. One set of plan.
2. Recommendation

Yours faithfully,


**DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES**