



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186208705698

Date: 11-11-2020

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: ANURAG JHUNJHUNWALAPARTNER OF SUORIMUS PROJECTS LLP
37C, HINDUSTAN ROAD KOLKATA - 700029

Sub: Fire Safety Recommendation for proposed two (02) nos. blocks as BLOCK –I (G +7) & BLOCK –II (G + 4) Residential building to the power of attorney “ANURAG JHUNJHUNWALAPARTNER OF SUORIMUS PROJECTS LLP” of 37C, HINDUSTAN ROAD KOLKATA - 700029 for the premises no. 23,Manick Bandopadhyia Sarani,(Moor avenue) , P.S.- Regent park, Ward -97, Borough –X ,under KMC Kolkata-700040

This is in reference to your application no. 0125186208705698 dated 18-07-2020 regarding the Fire Safety Recommendation for proposed two (02) nos. blocks as BLOCK –I (G +7) & BLOCK –II (G + 4) Residential building to the power of attorney “ANURAG JHUNJHUNWALAPARTNER OF SUORIMUS PROJECTS LLP” of 37C, HINDUSTAN ROAD KOLKATA - 700029 for the premises no. 23,Manick Bandopadhyia Sarani,(Moor avenue) , P.S.- Regent park, Ward -97, Borough –X ,under KMC Kolkata-700040

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

CONSTRUCTION:

- 1.The whole construction will be constructed as per approved plan drawings conforming the relevant building rules of local Corporation/Municipality Body.
- 2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- 3.Provision of ventilation at the crown of the central core-duct of the building shall be provided each blocks.
- 4.Arrangement shall have to be made for sealing all the vertical and horizontal ducts by the materials of adequate fire resisting capacity in each block.
- 5.Doors and windows should be of at least two hrs. fire resisting type.

OPEN SPACE AND APPROACH:

- 1.The open spaces surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire Appliances with turning facility.
- 2.The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting 45M.T.
- 3.The width and height of the access gate into the premises shall not be less than 4.5 mts. and 5.0 mts. respecting the abutting road.
- 4.Drive way should be free from any type of obstruction. No parking will be allowed on the drive way.
- 5.All the Passage way should be kept clear for free access.

STAIRCASE:

- 1.The staircases of the buildings shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having Fire Resisting capacity not less than 4 hours .
- 2.The staircases of the building shall have permanent vents at the top and openable sashes at each floor level in the external walls of the building.
- 3.The width of the staircases shall be made as marked in the plan. Corridors and the exit doors shall conform the relevant Building Rules with up to date amendment.
- 4.The staircases shall be extended up to open terrace of the building and shall be negotiated to each floor & each other & FCD shall be installed as marked/ shown in the plan drawing. The refuse area to be protected with the FCD with self-closing type openable in the direction of escape.

LIFT:

- 1.The walls of the lift enclosure shall be at least two hours Fire Resisting type.
- 2.Collapsible gate shall not be permitted.

Means of escape:

- 1.The emergency exit shall not be allowed to lock and key round the clock.
- 2.The walls of the lift enclosure shall be at least two hours fire resisting type. Collapsible gate shall not be permitted.
- 3.Time of evacuation should be as per IS: 1644-1988.

FIRE FIGHTING WATER:

Underground water reservoir having water capacity of 100000 ltrs. and overhead water reservoir having capacity of 10000 ltrs. Each block exclusively for fire fighting purpose with replenishing arrangements @ 1000 ltrs/min. preferably from two different sources of water supply shall be provided. The water reservoirs shall have overflow arrangement with the domestic water reservoir (if any) as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

HYDRANT SYSTEM:

- 1.External Hydrant System: IS-13039:1991

The whole area of the building is to be protected by adequate no. of pillar type hydrants system / Ring Main Hydrant of 100 mm internal dia. Pipe line i.e. one pillar hydrant per 1000 sq. meter of area or as per the vulnerability of the place.

- 2.Hydrant/ Wet Riser System IS-3844:1989

The building shall be provided with Wet Riser of 100 mm internal diameter pipeline with provision of landing valves at the staircase landings/ half landings at the rate of one such riser for 1000 Sq.mtr. of floor area. The system shall be so designed that kept charged with water all the time under pressure and capable of discharge 2850 ltrs./min. at the ground floor level outlet and minimum 900 ltrs./ min. at the top most furthest outlet. In both cases the running pressure shall not be less than 3.5 kgs./ Sq.mtr.. All other requirement shall conform I.S. 3844-1989.

Hose reel system

Provision for Hose Reel in conjunction with Wet Riser shall be made at each floor level and conforming the relevant I.S. IS:844-1985 Specifications.

Small gears

Hose box, 15 meter length delivery hose, gunmetal short branch of half inch dia. one set at each pillar hydrants as IS:903-1993 specification should be installed.

Pumps for fire fighting

one no. electric and one diesel driven(stand by) pump of capacity 2280 litre/min and one electric pump of capacity 180 litre/min should be installed and arranged in such a manner so that it will start automatically due to fall in pressure by installing as jockey pump as per IS-12469:1988 specification. All the pump shall be designed so as to supply water 900 LPM at a pressure 3.5 kg/cm² at the furthest point. Electrical and diesel driven arrangement for stand by fire pump shall be ensured. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be wet riser cum down comer with suitable terrace pump with overhead tank.

Sprinkler System:

Entire covered ground floor car parking area should be covered with the sprinkler head as per IS 9972. Alarm gang to be incorporated along with the sprinkler system.

ELECTRICAL INSTALLATION AND DISTRIBUTION:

- 1.The electrical installation including Transformers, Switch Gear, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in I.S. specification 1946-1982.
- 2.The vertical and horizontal electrical ducts shall be sealed at each floor level by fire resisting materials.
- 3.The electrical installation shall be adequately protected with CO₂/D.C.P. Fire Extinguishers conforming I.S. specification.
- 4.All cables should be FRLS type and all wiring along with appropriate gauge and resistance conforming the machineries to be used.
- 5.All electrical installation should be done in accordance with National Electrical Code and Part- VIII "Building Services" Section-2 "Electrical installation" good practice[4(10)].
- 6.Arrangement for alternative power supply shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Deep Tube-Well Pump, Fire Alarm System etc. and also for illuminating the Staircase, Corridors, Lobbies etc. and other places of assembly of the building in case of normal power failure.

DETECTION AND ALARM SYSTEM:

- 1.Manually operated Electrical Fire Alarm System with at least three numbers of break glass type call boxes fitted with Hooters along with Public Address System at each floor connecting with visual panel board shall be made in Control Room. The Control Room shall be located at entrance of ground floor of the building, other requirements of the system shall be made conforming I.S. 2189:2008.
- 2.Hooters will be sounded in such a manner so that an operation of a Detectors/ Manual Call Point. Hooters will be sounded on the same floor and immediate alternate floor.
- 3.Public Address System linked between all floors and Control Room shall have to be established.
- 4.Auto Fire Detection System with the help of Smoke Detectors shall be installed in all entire area of the ground floor of the building. The system shall also be made in place of rooms where valuable articles have been kept. The other requirements of the system shall be made in accordance with I.S. 2189:2008(as amended) and the code of practice as laid down in the N.B.C Part-IV.
5. Fire Control Room of the premises having direct dialing facility to the local fire service.
6. Both way public address system shall be made available in all floors of the building. The system shall be connected to the Main Control Room.

Gas Bank's 6044-2000:(if any)

In case of gas bank, the same should be installed conforming S/L 4.1.5 & 4.1.6 of the aforesaid IS code of practice and Fire service license to be obtained for such LPG gas bank.

First Aid Fire Fighting System

First Aid Fire fighting arrangement in the style of placing suitable type of portable fire extinguisher, Fire buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with IS 2190-1992.

AIR CONDITIONING SYSTEM (If any):

- 1.The A.H.U. shall be separated for each floor with the system. Air Ducts for individual floors.
- 2.Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System.
- 3.The system of auto shut down of A.H.U. shall be incorporated with the Auto Detection and Alarm System.
- 4.The Air Handling Units room shall not be used for storage of any combustibile First Aid Fire Fighting arrangement in the style of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

GENERAL RECOMMENDATIONS:

- 1.Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
- 2.Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
- 3.Floor numbers and directional sign of escape route shall be displayed prominently.
- 4.The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
- 5.Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
- 6.A crew of trained Fireman under the experienced Fire Officer shall be maintained round the clock for safety of the building.
- 7.Mock Fire practice and Evacuation Drill shall be performed periodically with participation of all occupants of the building.
8. A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

On compliance of all the above Revise Fire and Fire Safety Recommendation, the Director General, West Bengal Fire & Emergency Services shall be approved for necessary inspection and testing of all the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B.: Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire safety recommendation will be treated as cancelled.

Signature Not Verified
Digitally signed by SAROJ
KUMAR BAG
Date: 2020.11.11 21:34:45 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services