



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services

Paschim Bardhaman Division, 1st Floor, Durgapur Fire Station Building, City Centre, Durgapur-16

Memo No.: FSR/211862506300012648

Date : 24-03-2025

From :
Divisional Fire Officer
Paschim Bardhaman Division
West Bengal Fire & Emergency Services

To :
Proposed G+4 Storied Residential Building Of Mr. Anup Mondal, Mrs. Anamika Mondal, Mr. Jeet Mondal
Developed By Ganesha Construction.
R.S Plot no. 2008, L.R Plot no. 4304, R.S Kh no. 613, Mouza Bhiringi, J.L no.119, P.S Durgapur, Dist. Paschim
Bardhaman.

Sub: Issuance of Fire Safety Recommendation for proposed construction of G+4 Storied Residential Building of
Mr. Anup Mondal, Mrs. Anamika Mondal, Mr. Jeet Mondal (Developed By Ganesha Construction) over R.S Plot no.
2008, L.R Plot no. 4304, R.S Kh no. 613, Mouza Bhiringi, J.L no.119, P.S Durgapur, Dist. Paschim Bardhaman..

Memo No.: FSR/211862506300012648

This is in reference to your AIN 211862506300012648 dated 19-Mar-2025 regarding Issuance of Fire Safety Recommendation for proposed construction of G+4 Storied Residential Building of Mr. Anup Mondal, Mrs. Anamika Mondal, Mr. Jeet Mondal (Developed By Ganesha Construction) over R.S Plot no. 2008, L.R Plot no. 4304, R.S Kh no. 613, Mouza Bhiringi, J.L no.119, P.S Durgapur, Dist. Paschim Bardhaman.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

Recommendation :

A. CONSTRUCTION:

1. Materials for rapid flame, toxic smoke / fumes spread materials / categories including untreated wood fiber board etc. shall not be used.
2. The whole construction of the proposed building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body /Kolkata Municipal



3. The floor area exceeds 750 Sq. Mts. shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.
4. The interior finish decoration of the building shall be made with low flame spread materials conforming I.S. specifications.
5. Provision of ventilation at the crown of the central core-duct of the building shall be provided.
6. Arrangements shall have to be made for sealing all the vertical and horizontal ducts by the materials of adequate Fire resisting capacity & the doors of service ducts / shafts of 2 hr. fire rating.

B. OPEN SPACE & APPROACH:

1. The open space surrounding the building shall be kept clear open to sky and shall conform the relevant building rules as well as permit the easy accessibility and maneuverability of Fire appliances having turning facility.
2. The approach roads & internal drive ways shall be sufficiently strong to withstand the load of Fire Engine weighting up to 45 M.T.
3. The width and height of the access gates into the premises shall not be less than 4.5 Mts. and 5 Mts. respecting abutting the road.

C. FIRE FIGHTING WATER:

1. Overhead Reservoir of 25,000 Liters Capacity is to be provided and will be kept full at all time on roof level of each tower.
2. UGWR for Fire fighting of 50000 Liters capacity is to be provided and will be kept full at all time as it has been proposed in plan drawing.
3. The Fire water reservoir shall have overflow arrangement with the domestic reservoir to avert stagnancy of water.
4. Provision of necessary manhole shall be made on the top of the reservoir as per specification.
5. Provision of replenishment at the rate of at least 1000 lts./min. shall be made.
6. The deep tube wells for the replenishment of the reservoir shall be incorporated with the auto starting facility with the actuation of auto detection and suppression arrangement of the premises and shall also be connected with dual power supply units.
7. Provision of placing Fire Appliances on the underground water reservoir to be made to draw water in case of emergency.

D. WATER LAYOUT SYSTEM :

a. Ring Main Hydrant System :

1. 100 mm dia Ring Main water layout arrangement along with adequate nos. of 3 way Fire Service inlet covering the entire premises of the project with provision of pillar type yard hydrants with door hose boxes, containing 2 lengths of 63 mm delivery hose and short branch pipe shall be provided at all the strategic location surrounding the building along with adequate nos. Fire Service inlet to be installed conforming I. S. 3844 – 1989 (up to date amendment).



one such Down Comer and Hose Reel per 1000 Sq. M of floor area.

2. Hose Reel Unit: - Provision of hose reel units on swiveling drum in conjunction with down comer near each landing valves shall be made in the building.
3. All other requirements of the water base Fire Protection System shall be made as per I. S. Specification 3844 – 1944 (with upto date amendment).

F. FIRE PUMP :

Provision of the fire pump of 900 LPM shall have to be made to supply water at the rate designed pressure and discharge into the Water based system, which shall be installed in the roof in connection with Overhead Water Reservoir.

One such pump shall always be kept on standby preferably be of diesel driven type.

G. ELECTRICAL INSTALLATION & DISTRIBUTION :

1. The electrical installation including transformers, Switch Gears, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in the I.S. specification 1946-1982.
2. The vertical ducts shall be supply sealed at alternative floor level.
3. The electrical installation shall be adequately protected with DCP Modular system.
4. Alternative Power Supply :

Arrangements shall have to be made to supply power with help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Alarm System, Fire Lift etc. and also for illuminating the Staircase, Corridors etc. and other places of assembly of the building in case of normal power failure.

H. DETECTION, ALARM AND SUPPRESSION SYSTEM :

1. Manually operated Electrical Fire Alarm System with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, talk back system at each floor connecting with audio-visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189-1988.
2. Hooter will be sounded in such a manner so that an operation of a Detector or Manual Call Point Hooters will sounded on the same floor and immediate alternate floor.
3. Public Address System :

Public Address System linked between all floors and Control Room shall have to be established.

I. FIRST AID FIRE FIGHTING SYSTEM :

First Aid Fire Fighting arrangement in the style of placing suitable type of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.



1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
2. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
3. Floor numbers and directional sign of escape route shall be displayed prominently.
4. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment installed in the building to keep them in perfectly good working conditions at all times.
6. A crew of trained Fireman under the experienced Officer shall be maintained round the clock for safety of the building.
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of the building.
8. Close circuit T.V. shall have to be provided for the entire floor area including the basement area of the building.

After issuance of this recommendation a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performances of all Life and Fire Safety arrangements and installation of the buildings. On compliance of all the above Fire and Life Safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation; Fire Safety Certificate in favor of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building. N.B. : Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.



Divisional Fire Officer
West Bengal Fire & Emergency Services