



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186218700364

Date: 25-03-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: GODAVARI ESTATES LLP
644, RABINDRA SARANI, KOLKATA - 700003. WARD - 07, BOROUGH-I.

Sub: Revised Fire Safety Recommendation for proposed G+V storied under group Residential Building at premises no. 644, Rabindra Sarani, Kolkata- 700003.

This is in reference to your application no. 0125188228700003 dated 05-01-2022 regarding the Revised Fire Safety Recommendation for proposed G+V storied under group Residential Building at premises no. 644, Rabindra Sarani, Kolkata- 700003.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

The revised plan drawings submitted by you were scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in favour of the aforesaid building subject to compliance of the earlier Fire Safety Recommendation which was issued vide this office memo no. FSR/0125186218700364 dt. 29.06.2021 will remain same and strictly to be followed.

In addition:

- i. One no standby booster pump of 900 LPM shall have to be provided.
- ii Under Ground Water Reservoir for fire of 50,000 ltrs shall have to be provided as shown in the plan.
- iii. 2nos smoke detectors shall have to be installed in Ground floor office area.

For GODAVARI ESTATES LLP

✓ *Manoj K. Banerjee*
Partner

Director
West Bengal Fire & Emergency Services

For GODAVARI ESTATES LLP

✓
Manoj K. Banerjee

Partner