WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LIMITED



(A Government of West Bengal Enterprise)

OFFICE OF THE ASSISTANT ENGINEER

BIDHANNAGAR CUSTOMER CARE CENTRE BIDHANNAGAR, DURGAPUR-713212 A1/7,SSB SARANI,SECTOR 2A, DURGAPUR-12

Memo No: AE/SM/BNCCC/ 1782

Dt: 04/09/24

To Susovan Roy, Kedarnath Construction, Project Name: Kalpana Enclave, Mouza: Gopinathpur, Durgapur, Paschim Bardhaman.

Sub: NOC for providing electric connection

Ref: Your prayer for NOC, Rec no 967 dated 04.09.2024

Dear Sir.

In reference to the above application received at this office on dated 04.09.2024, NOC i.r.o your proposed project of Residential Building at R.S. Plot NO. - 4931, LR No. 3757, J.L. No. -85, Mouza: Gopinathpur, P.S. - Coke oven, Durgapur-713201 may be given subject to the following:

1. Total cost for development of the infrastructure (i.e. installation of distribution transformer, drawal of LT and HT line, meter connection etc.) to serve the contractual load demand shall be borne by the consumer as per WBSEDCL Scheme and the entire work will be carried out under the supervision of WBSEDCL. It may be presumed that, the consumer is ready to wait for the new electric connection, until the aforesaid infrastructure is developed and is capable to serve the demand load.

2. Necessary way leave (as per clause no 3.2.1/c of notification 46 of WBERC) for installation of new

transformer and other LT and HT network, must be arranged by the consumer.

3. The entire LT and HT system and network will be the property of WBSEDCL.

4. An agreement must be executed in the prescribed format annexed with the form.(application form for the

new electric connection in residential/commercial complex)

5. The consumer must ensure minimum necessary safety clearance from the existing L&MV electrical lines. The mandatory clearance of any building from any existing L&MV overhead lines as per Electricity Act. 2003 is reproduced below:-

SI No	Mandatory clearance in Meter (feet)	L&MV (upto 11KV)
1	Vertical clearance of OH line from highest point of the	
2	Horizontal clearance of OH line from nearest point of the building/structure (permanent/temporary)	1.2 Meter (4 feet)

This is for your kind information and necessary action please.

Thanking you,

Station Manager Bidhannagar C.C.C W.B.S.E.D.C.L