



सत्यमेव जयते

Government of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services

Station Feeder Road, P.O & P.S Siliguri, District: Darjeeling, Pin – 734005

Memo No.: FSR/211862506300016077

Date : 23-Jul-2025

From :
Divisional Fire Officer
Darjeeling Division
West Bengal Fire & Emergency Services

To :
Smt. Gita Chakraborty & Others All Are Represented By Their Constituted Attornie Pragati Construction
MOUZA-SILIGURI (R.S.),SILIGURI PURBA (L.R.),PLOT NO-13259(R.S.),8234(L.R.),WARD NO-22,P.S.-SILIGURI,DIST-DARJEELING

Sub : Demand Notice under Section 11E of WBFES Act 1950 as amended for issue of Issuance of Fire Safety Recommendation for the Proposed G+5 Storied Residential cum Commercial Building under group Residential in name of Smt. Gita Chakraborty & Others All Are Represented By Their Constituted Attornie Pragati Construction having MOUZA-SILIGURI (R.S.),SILIGURI PURBA (L.R.),PLOT NO-13259(R.S.),8234(L.R.),WARD NO-22,P.S.-SILIGURI,DIST-DARJEELING.

This is in reference to 211862506300016077 towards the application submitted by you in respect to the above proposal, this is to inform you that, the **Fire Safety Recommendation** in respect of the above building along with the approved plan will be issued subject to the payment of fee amounting to Rs. **12579 (Twelve Thousand Five Hundred Seventy Nine)**

You are hereby requested to remit the above amount within **15 (fifteen)** days from the date of issuance of this demand notice.

1. Abutting Road Width (in meters): 7.61
2. Total Floor Area (in Sq. meters): 2887
3. Height of the Building(in meters): 19.50
4. Type of Principal Occupancy: Residential
5. Demand Amount(in INR): 12579 (Twelve Thousand Five Hundred Seventy Nine)

Mode of Payment:

You are requested to deposit the above demand fees under the Head of Account **0070-60-109-001-14(0070– Other Administrative Service, 60-109-Fire Protection of Control, 001 – Fees Under the West Bengal Fire Services Act, 14 – Service Fees)** by online mode only available through the **Make Payment Option** after logging into the **WB e-District Portal** using your login user id and password used for





Government of West Bengal GRIPS 2.0 Acknowledgement Receipt Payment Summary



230720252017447895

GRIPS Payment Detail

GRIPS Payment ID:	230720252017447895	Payment Init. Date:	23/07/2025 15:48:50
Total Amount:	12579	No of GRN:	1
Bank/Gateway:	SBI EPay	Payment Mode:	SBI Epay
BRN:	5863437001033	BRN Date:	23/07/2025 15:49:16
Payment Status:	Successful	Payment Init. From:	Department Portal

Depositor Details

Depositor's Name: Saurabh Eiram
Mobile: 9064760643

Payment (GRN) Details

Sl. No.	GRN	Department	Amount (₹)
1	1320252600174478978	WB e-distric	12579
Total			12579

IN WORDS: TWLEVE THOUSAND FIVE HUNDRED SEVENTY NINE ONLY.

DISCLAIMER: This is an Acknowledgement Receipt, please refer the respective e-challan from the pages below.





Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri, District: Darjeeling, Pin – 734005

Memo No.: FSR/211862506300016077

Date : 23-07-2025

**From :
Divisional Fire Officer
Darjeeling Division
West Bengal Fire & Emergency Services**

**To :
Smt. Gita Chakraborty & Others All Are Represented By Their Constituted Attornie Pragati Construction
MOUZA-SILIGURI (R.S.),SILIGURI PURBA (L.R.),PLOT NO-13259(R.S.),8234(L.R.),WARD NO-22,P.S.-
SILIGURI,DIST-DARJEELING**

Sub: Issuance of Fire Safety Recommendation for the Proposed G+5 Storied Residential cum Commercial Building under group Residential in name of Smt. Gita Chakraborty & Others All Are Represented By Their Constituted Attornie Pragati Construction having MOUZA-SILIGURI (R.S.),SILIGURI PURBA (L.R.),PLOT NO-13259(R.S.),8234(L.R.),WARD NO-22,P.S.-SILIGURI,DIST-DARJEELING..

This is in reference to your AIN 211862506300016077 dated 22-Jul-2025 regarding Issuance of Fire Safety Recommendation for the Proposed G+5 Storied Residential cum Commercial Building under group Residential in name of Smt. Gita Chakraborty & Others All Are Represented By Their Constituted Attornie Pragati Construction having MOUZA-SILIGURI (R.S.),SILIGURI PURBA (L.R.),PLOT NO-13259(R.S.),8234(L.R.),WARD NO-22,P.S.-SILIGURI,DIST-DARJEELING.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

Recommendation :

A) Construction Part:-

- i) The whole construction of the proposed building shall be carried out as per approved plan of the Municipality/local authority & conforming the relevant building rules of said local authority.
- ii)The floor area exceeds 750 sq.miter shall be suitably compartmented by separation walls up to ceiling level having at least two hrs fire resisting capacity.
- iii) The interior finish decoration of the building shall be made of low flame spread materials conforming I.S Specification.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862506300016077

- iv) All construction materials should be of four hrs. Fire resisting type.
- v) Doors & windows should be of at least 2 hrs of fire resisting type.
- vi) All opening of services ducts, void, gap, joints etc. should be sealed with fire check materials.
- B) Open Space & approach:-
- i) The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of fire appliance with turning facility.
- ii) The approach roads shall be sufficiently strong to withstand the load of fire engine weighting up to 45 M.T.
- iii) The width and height of the access gates into the premises shall not be less than 4.5 miters & 5 miters respectively abutting the roads.
- C) Means of escape: -
- i) The Staircases of the building shall be enclosed type & construction shall be made of bricked/RCC type having fire resistance capacity not less than 4 hrs.
- ii) Time of evacuation should be as per I:S 1644-1988 i.e. 2.5 minutes.
- iii) The width of the staircases shall be 1.25 miters. Corridors of the building and the exit doors shall conforming the relevant building rules.
- iv) The staircases shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.
- v) Fire & Smoke doors at the entrance of all the staircases enclosures at each floor level shall be provided. The F.C.D shall be at least two hour fire resisting with self closing type open able in the direction of the escape.
- vi) In no way the travel distance from any point of the building exceeds the limit of 22.5 miters.
- vii) The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
- viii) Parking area should not used for any storage.
- ix) There should be two staircases from the ground floor to the terrace of the building.
- D) Electrical Installation: 1946:1982:- (I:S-694)
- i) All electrical installation should be done in accordance with National Electrical code & part –viii “Building Service” section -2 “Electrical installation” good practice.[4(10)].
- ii) All cable should be of FRLS type & all wiring should be done by the copper wire along with appropriate gauge such as 1.2 sq. mm for light , fan, bulbs etc. 2.5 sq. mm for freeze, TV & 4 sq. for geezer, washing machine etc. less than 0.2M2.
- iii) Electrical installation shall be tested by the licensed Electricians where as 85 % fire originated from electrical source of energy.
- E) In-case of Air Condition:- I:S 659-1991:- It shall conform to the following:-
- i) Escape routes like corridors, lift lobbies etc. shall not be used as return air passages.
- ii) Regular checkup of all split type window machine to prevent dust, foreign materials in the air inlet should maintained to prevent spontaneous combustion.
- iii) In case of central A.C. system , the same shall be incorporated with automatic dampers with fusible link with a view to shut down the system automatically.
- iv) Regular checking, testing, cleaning the Air inlet is must.
- v) AHU room shall not be used for storage of combustible articles.
- F) IF L I F T
- 1) Walls of all lift enclosures shall have a fire rating of 2 h; lifts shafts have a vent area not less than 0.2M2.
- 2) Lift Motor Room shall be located preferably on top of the shaft and separated from the shaft by the floor of the room.
- 3) Landing doors in all lift enclosures shall have a fire resistant of not less than half hour.
- 4) All Lift Car door shall have a fire resistance rating of half an hour.
- 5) Exit from the lift lobby, if located in the core of the building, shall be through a self closing smoke stop door of half an hour fire resistance.
- 6) Grounding Switch(es), at ground floor level shall be provided on all the lifts to enable the fire service to ground the lifts.
- 7) A sign shall be displayed and maintained on every floor at or near the lift including that in case of fire, occupants shall be the stairs unless instructed otherwise. The sign shall also contain a plan for each floor showing the location of the stairways.



8) The lift shall have a floor area of not less than 1.4m². It shall have landing capacity of not less than 545 kg (8 persons lift) with automatic closing doors of minimum 0.8m width.

9) In case of failure of normal electric supply, it shall automatically trip over to alternate supply. For apartment houses, this changeover of supply could be done through manually operated changeover switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand still with door open.

G) Alternate power supply :-Arrangement shall be made to supply power with the help of a Generator to operate at least the fire pump, pump for deep tube-well, illumination of stairs, corridors, means of escape etc. in case of normal power failure

H) Fire Fighting Water: -

i)The building should be provided with 50000 liters capacity of underground stored water with replenishing arrangement @ 1000 liters of water per minutes preferably from two different sources. The height of the reservoir should not be exceeding 30 cm from the ground level .Fire water reservoir shall have overflow and connected with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all times.

ii)The location of the underground reservoir should be such so that Fire Service vehicles may get access to the site of the reservoir with a view to draw the water from the said reservoir..

I) Terrace Tank:-One Terrace Tank of capacity Minimum 10000 liter should be installed in the building along with suitable terrace pump & wet riser cum down comer system.

J) Hose Reel System:-IS 884-1985, the Hose reel hose system should be provided at each floor of the building. The internal dia of the said hose reel shall be 19 mm to 32 mm and the discharge capacity not less than 22.5 LPM. While the length of the hose reel not more than 36.50 meters. The distance of such Installation should be in such a way that no part of the floor is more than 6 meters distance from a hose nozzle when fully extended.

K) Pumps for fire fighting Installation.IS-12469-1988.

i)The pump should be installed and arranged in such manner so that it will start automatically due to fall in pressure as prefixed in the installation by installing a Jockey pump. As per NBC the discharge capacity of the said pump minimum 900 liters per minutes,

ii) All the pumps shall be so designed as to supply water at the designed pressure and discharge into the water based system which shall be installed in the building.

iii) One such pump shall always be kept on stand by preferably be of diesel driven type.

iv)All the pumps shall be incorporated with both normal and auto starting facilities, the suction of the pump shall preferably of positive type or in case of negative suction the system shall be wet riser- cum- down comers with suitable terrace pump fitted with over head tank.

L) Small gears:-I:S 903-1993:- Hose box, 1.5 meters permoline delivery hose & gun metal short branch half inch dia @ one set each at or near all the pillar hydrant, landing valve on all floors of the building should be installed.

M) Internal Hydrant System: - IS-3844:1989.

i) Pressurized wet risers of 100 mm dia each should be provided at each staircase with provision of landing valve at each landing and half landing @ one such riser for each 1000 sq. meters of floor area of the building. This system shall be designed in such a manner that it should be kept charged with water at all time and capable of discharge 2850 liters of water per minutes at the ground level & minimum 900 liters per minutes at the top most outlets.

ii) In both the cases, the running pressure at ground level shall be 3.5 kg/esq c.m & 2.5 kg per esq.cm at the top most landing valves should be ensured.

N) First aid fire fighting system:-IS 2190-1992. Sufficient Nos. of Portable fire extinguishers of DCP type, Water type and Sand and water bucket should be provided at different places of the building and it should be within the reach of all concern as stated in the IS Code i.e. one no.@ 1000 sq.meters floor area or as per the vulnerability.

O) Detection & Alarm System, Suppression system & Public address system-IS 2189-1988. Sufficient Nos. of manually operated electrical fire alarm system of break glass type call boxes and fitted with alarm like Hooters with public address system, talk back system at different places of the building should be installed & connecting with audio visual panel board shall be made in Control Room as per the IS Code of practice. The control room shall be available in the ground floor.

P)SPRINKLER INSTALLATION:

The automatic sprinkler installation shall be provided of the building as per I.S. specifications. Alarm Gong



to be incorporated along with the sprinkler system.

Q) Lighting Protection of the Building: - This protection for buildings shall be provided.

R) General recommendations: -

i) Mock drill & evacuation drill should be conducted periodically & in this regard a register for the recording of mock fire drill, evacuation drill, testing and checking of whole fire fighting installation, electrical installation should be maintained & shall be liable to produce the same to the authorized Officer of this department on demand.

ii) Fire notice for fire fighting and evacuation from the building should be provided and shall be displayed at all places of the building as per clause 5.5 of N.B.C.

iii) Floor No. and Directional Sign of escape route should be displayed prominently as per clause 5.5 of the N.B.C. Code. (Auto glow type).

iv) All the occupants and other peoples shall be conversant with the installed fire fighting equipments of the building so that they can operate the same in case of exigency.

v) Arrangement shall be made for regular checking, testing and proper maintenance of all fire fighting equipments and keep them in good working condition at all time it should be written in the Register.

vii) Good house keeping should be maintained.

Note-

i) The fire service recommendations are issued subject to the free from any court case or legal re-encumbrances.

ii) This shall be treated as provisional N.O.C. On compliance of all the fire and life safety recommendations, The deputy Director (NZ), West Bengal Fire & emergency Services shall be approached for necessary inspection and testing of the installation.

Final Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the test and safety performance of safety aspects of the installation of the building.

Memo No.: FSR/211862506300016077



Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862506300016077