

West Bengal State Electricity Distribution Company Limited

(A Govt. of W.B. Enterprise)

Office of the A.E & Station Manager, Midnapore CCC

Power House, Burdge Town, Paschim Medinipur, Pin - 7221101 Phone: 032222275521, E-mail: sm.midnapur@wbsedcl.in

Date: 19/8/4

Memo. No.MCCC/ 138 % TO
BISWANATH GHOSH
'THE 69 YOUR NEXT HOME'
RANGAMATI, ARJAMA APARTMENT,
MIDNAPUR, PIN-721101
PHN-9732595653

SUB: NOC for site plan showing area for proposed G+3 storied residential Apartment Building of 1)SRI BIBHAS KUMAR SANYAL 2) SRI BIKASH KUMAR SANYAL, BOTH S/O SRI PRABHAS SANYAL At Mouza-Sekhpura, J.L. NO.-172, R.S. PLOT NO.-213(PART), L.R. PLOT NO.-2341(PART),SUBPLOT NO.-5(PART) & 6(FULL), WARD NO-05 P.S.-KOTWALI, DIST- PASCHIM MEDINIPUR,Under Midnapore Muncipality. Legal Reprentative Executors, Administration & Assigns In Favour Of 1) BISWANATHJ GHOSH, 2)MITALI GHOSH Being partners of 'THE 69', ARJAMA APARTMENT, RANGAMATI under Midnapur Customer Care Centre.

- 1. Necessary way leave to be provided by intending consumer.
- 2. Intending Consumer to apply through Procedure B for new service connection
- 3. Intending Consumer to follow IE rule during his construction
- 4. Intending Consumer to give suitable location in his/her plot for installation of WBSEDCL equipments.

Following mandatory clearance to be provided from any OH line from any building as per electricity Act 2003.

- 1. Vertical Clearance of OH line from heighest point of building is 2.5 mtr for L&MV upto 440 V and 3.7 mtr for HV(11 KV).
- 2. Horizontal Clearance of OH line from nearest point of building 1.2 mtr for L&MV (upto 440 V) and 1.2 mtr for HV(11 KV).

Intending applicant will apply for construction power service connection for his construction work & surrender 2 nos existing domestic meter (L4070254, G274881).

Yours faithfully

A.E & Station Manager Midnapore Customer Care Center

