



Government of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services

Jalpaiguri Fire Station, Race Course Para, P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo No.: FSR/211862406300009368

Date : 25-12-2024

From :  
Divisional Fire Officer  
Jalpaiguri Division  
West Bengal Fire & Emergency Services

To :  
Sri. Jagannath Dey, Sri. Jayanta Dey, Smt. Manju Kar, Smt. Shikha Roy Bardhan & Smt. Sarmistha Laha Dey Sarkar  
MOUZA-DABGRAM,PLOT NO-135(R.S.),15(L.R.)WARD NO-33(S.M.C),NEW MILAN PALLY,P.S.-NEW  
JALPAIGURI,DIST-JALPAIGURI,PIN-734007

Sub: Issuance of Fire Safety Recommendation for G+3 Residential building under occupancy group"  
Residential " in favour of Sri. Jagannath Dey, Sri. Jayanta Dey, Smt. Manju Kar, Smt.  
Shikha Roy Bardhan & Smt. Sarmistha Laha Dey Sarkar having site at MOUZA-DABGRAM,KH  
NO-136,120(RS),405(LR),PLOT NO- 191(RS),17(LR),WARD NO-41,JYOTI NAGAR,P.S.-  
BHAKTINAGAR,DIST-JALPAIGURI.

This is in reference to your AIN 211862406300009368 dated 17-Dec-2024 regarding Issuance of Fire Safety Recommendation for G+3 Residential building under occupancy group"  
Residential " in favour of Sri. Jagannath Dey, Sri. Jayanta Dey, Smt. Manju Kar, Smt.  
Shikha Roy Bardhan & Smt. Sarmistha Laha Dey Sarkar having site at MOUZA-DABGRAM,KH  
NO-136,120(RS),405(LR),PLOT NO- 191(RS),17(LR),WARD NO-41,JYOTI NAGAR,P.S.-  
BHAKTINAGAR,DIST-JALPAIGURI

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

**Recommendation :**

**A) Construction Part:-**

- i) No addition and alteration of the building shall be allowed without the concurrence of the department,
- ii) Risk factor of the building shall be reduced.

**(B) Electrical Installation : 1946:1982 ( I:S-694)**

- i) All electrical installation should be done in accordance with National Electrical Code& Part –VIII



"Building Service Section-2"Electrical installation " good practice.[4(10)].

(ii) All cable should be of FRLS type & all wiring should be done by the copper wire along with appropriate gauge such as 1.2 sq. mm for light, fan, bulbs etc. 2.5 sq. mm for freezer, T.V. & 4 Sq. mm for geyser, washing Machine etc.

(iii) Electrical installation shall be tested by the licensed Electricians where as 85% fire originated from electrical source of energy.

(C ) Alternate power supply : Arrangement shall be made to supply power with the help of a Generator to operate at least the fire pump for deep tube-well , illumination of stairs, corridors, means of escape etc, in case of normal power failure.

(D) Hose Reel System: IS 884-1985, the Hose reel hose system should be provided at each floor of the building. The internal dia of the said hose reel shall be 19mm to 32mm.

E) Open Space & approach:

i) The open space available in the building will be kept free of obstruction at all time.

ii) The escape routes of the building should be kept free from any obstruction.

iii) The entrance route of the building should not be obstructed by any way and the width & height of the access gate shall be not less than 4.50 meters and 5.00 meters respectively.

F) Adjacent Fire Risk:

i) The risk to be avoided by keeping open space in between the buildings.

G) Means of Escape:

i) Separate entrance and exits should be provided in every room of the office, class, library & Laboratory.

H) Terrace Tank for firefighting water: One or more than one Terrace Tanks of capacity Minimum 5000 liters Should be provided in the building along with suitable terrace pump & down comer and the discharge capacity not less than 450 LPM . While the length of the hose reel not more than 36.350 meters. The distance of such installation should be in such a way that no part of the floor is more than 6 meters. Distance from a hose nozzle when fully extended.

I) Detection and Alarm System, suppression system and public address system: IS: 2189:1988:

i) Manually operated electrical fire alarm system of break glass type call boxes with hooters, public address system and talk back system should be installed in different vulnerable points of the building and the storage area.

J) Small Gears: IS 903:1993: Hose Box ,15 meters permline delivery hose & gun metal type short branch of half inch dia @ one such set each at the or near all pillar hydrant, landing valves on all area should be installed.

K) First Aid Fire Fighting System: 2190:1992

i) First Aid fire fighting arrangement in the style of placing suitable type of portable fire extinguishers of different types, such as ABC type, Co2 type, Sand and Water fire buckets, etc. Should be installed in all vulnerable locations of the premises of the office , Laboratory ,Library area and other places in accordance with the I.S. code of practice.

l) The protection for buildings shall be provided as given in Part VIII building Services, Section-2 Electrical installation.

General Recommendation:

1) Employee and security staff shall be conversant with installed fire fighting equipments of the building on to operate in the event of fire and testing .

2) Arrangement shall be made for regular checking, testing and proper maintenance of all the fire safety installation and equipment installed in the building to keep them in perfectly good working conditions at all times.

3) Mock fire practice and evacuation drill should be performed periodically with participation of all occupants of building.

4) Good housekeeping and regular cleaning should be done regularly.

5) Combustible articles should be separated from the noncombustible articles.

6) Electrical transformer, generator etc. Should be in safe distance from the combustible articles.

7) Protection of personnel and provision of means of escape to be provided to avoid being exposed to or being trapped in fire or toxic fumes.



8) Elimination of all avoidable sources of ignition and confining all unavoidable sources of ignition.

Memo No.: FSR/211862406300009368



Signature valid

Digitally Signed.  
Name: DEVAN LERCHA  
Date: 25-Dec-2024 12:39:35  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862406300009368