



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.: FSR/0125186220200020

Date : 26-06-2025

**From :
Director
Fire Prevention Wing
West Bengal Fire & Emergency Services**

**To :
COMMERCIAL COMPLEX , BENGAL SHRIRAM HITECH CITY PVT LTD
Konnagar, Khurdabahera, Barabahera, Kotrang, Bhadrakali, Makhla-Mouza, P.S.-Uttarpara, Dist.-Hooghly, West Bengal**

Sub : Revise Fire Safety Recommendation for a proposed G+5 storied mixed occupancy building which will be constructed at Konnagar, Khurdabahera, Barabahera, Kotrang, Bhadrakali, Makhla- Mouza, P.S.- Uttarpara, Dist.- Hooghly, West Bengal..

This is in reference to your AIN 211882506300001752 dated 19-May-2025 regarding the Revise Fire Safety Recommendation for a proposed G+5 storied mixed occupancy building which will be constructed at Konnagar, Khurdabahera, Barabahera, Kotrang, Bhadrakali, Makhla- Mouza, P.S.- Uttarpara, Dist.- Hooghly, West Bengal..

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the

Recommendation :

1. The Fire Safety Recommendations as served earlier vide memo no. FSR/0125186220200020 dated 28.03.2022 will remain unchanged.
2. Staircase pressurization shall be done as shown in the plan drawing and as per N.B.C. Part-



Director
West Bengal Fire and Emergency Services