

(37) 08/01/2025

THE KOLKATA MUNICIPAL CORPORATION
WATER SUPPLY DEPARTMENT

SAVE WATER SAVE LIFE

SANCTION ORDER

SAVE WATER SAVE LIFE

(Sanction/Permission for private water supply connection/or
Other works under provisions of sections

i) 258 read with sec. 558

ii) 254 read with sec. 260

iii) 235,236,239 read with sec. 260 of CMC Act, 1980)

Building Case No.: 2024010049

Date: 28/06/2024

Building Plan Sanction No.: 2024010077

Date: 18/12/2024

Borough No.: 01

Ward No.: 004

Assessee No.:

110040200137

Premises No. & Street Name: 26

BEERPARA LANE

Owner Name: PLINTH ROOF REALTORS LLP,

Name of KMC Licensed Plumber: SRI KRISHNENDU GHOSH

Address of Plumber: SERPENTINE LANE, CAL-14. 700014

Purpose: CONSTRUCTION

NEW

Budget Code	Description	Amount
4231/211	Deposit money for water connection - 4231/211	0
4231/212	Road opening fees - 4231/212	356
4231/231	Extra road restoration - 4231/231	52745
4210/221	Annual fees for domestic purpose water supply - 4210/221	0
4210/262	Sale of water for non domestic purpose (ICI) - 4210/262	0
4210/299	Miscellaneous - 4210/299	374
4231/211	Fees for water connection - 4231/211	20000

Total Amount: 73475

Receipt No.: E/07/2024/5307

Date: 17/12/2024

Mode of Payment: Online

Details of Water Fittings:

Stop Cock Size: 25 Service Pipe Size: 25 Water Tap Size: 15 Ferrule Size: 25

Road Opening Date: From 10/01/25 to 11/01/25

Note:

1) The above demand amount excludes physical execution of the work through KMC licensed plumber involving material, manpower & tools & plant cost.

2) Owners of the premises shall have to maintain all water fittings to prevent stagnation due to leakage & drain off water once a week from underground & overhead reservoirs and covered properly with well fitted lids for safeguard against contamination and mosquito breeding. Non-compliance may lead to cut off water connection u/s 275(b) of CMC Act, 1980 and will be treated as offence u/s 496 of the CMC Act. Ball cock is to be installed at underground reservoir to save water. It is also encouraged to install automatic pump tripping arrangement to avoid overflow from overhead reservoir.

** As this is a computer generated document, it does not require actual signature **

Assistant Engineer(W.S)

Executive Engineer(W.S)