



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.: FSR/211862506300018316

Date : 27-11-2025

From :
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
Plotted Development On Parcel 9, Bengal Shriram Hi - Tech City Pvt Ltd, Shriram Grand City
KH. NO-4129, MOUZA-BARABAHERA, JL NO-05, LR DAG NO-3444 AND KH. NO-11978, MOUZA-KONNAGAR, JL
NO-07, HOOGHLY-712246

Sub: Fire Safety Recommendation for Proposed Construction of Commercial Building (G+I) storied under group of Mercantile Building & Club Building (G+I) storied under group of Assembly in the name & style of "SHRIRAM GRAND CITY" (An Integrated It Township And Automotive Ancillary Park) Located At Uttarpara, Hooghly Falung Under Kanaipur Panchayat, Mouza-Barabahera, J.Lno-5, Khatian No-4129, Dag No-3444(P) And Mouza-Konnagar, J.L.No -7 Khatian No-11976, Dag No-4476(P), P.S.- Uttarpara, Dist.- Hooghly, West Bengal Pin-712246..

This is in reference to your AIN 211862506300018316 dated 27-Oct-2025 regarding Fire Safety Recommendation for Proposed Construction of Commercial Building (G+I) storied under group of Mercantile Building & Club Building (G+I) storied under group of Assembly in the name & style of "SHRIRAM GRAND CITY" (An Integrated It Township And Automotive Ancillary Park) Located At Uttarpara, Hooghly Falung Under Kanaipur Panchayat, Mouza-Barabahera, J.Lno-5, Khatian No-4129, Dag No-3444(P) And Mouza-Konnagar, J.L.No -7 Khatian No-11976, Dag No-4476(P), P.S.- Uttarpara, Dist.- Hooghly, West Bengal Pin-712246.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

Recommendation :

CONSTRUCTION:

1. The whole construction of the building shall be carried out as per approved plan drawings conforming the relevant building rules of Municipal/local Body .
2. The floor area exceeds 750 m² shall be suitably compartmented by separation walls up to ceiling level having two hours fire resisting capacity.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862506300018316

3. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
4. Provision of ventilation at the crown of the central core duct of the building shall be provided.
5. Arrangement shall have to be made for sealing all the vertical and horizontal ducts by the materials of adequate fire resisting capacity.

OPEN SPACE AND APPROACH:

1. The open spaces surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire Appliances with turning facility.
2. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting 45M.T.
3. The width and height of the access gate into the premises shall not be less than 4.5 mts. and 5.0 mts. respecting the abutting road.
4. Drive way should be free from any type of obstruction. No parking will be allowed on the drive way.
5. All the Passage way should be kept clear for free access.

STAIRCASE:

1. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having Fire Resisting capacity not less than 4 hours.
2. The staircase of the building shall have permanent vents at the top and openable sashes at each floor level in the external walls of the building.
3. The width of the staircase shall be made as marked in the plan. Corridors and the exit doors shall conform the relevant Building Rules with up to date amendment.
4. All the staircase shall be extended up to terrace of the building and shall be negotiated to each floor.
5. Fire and smoke doors at the entrances of all the staircase enclosures as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least one hour Fire Resisting wire glass window fitted with self-closing type openable in the direction of escape.

FIRE FIGHTING WATER:

Underground water reservoir having water capacity of 50,000.Ltrs. & Overhead water reservoir 21,000 Ltrs. (as shown in the plan) exclusively for fire fighting purpose with replenishing arrangements @ 1000 Ltrs./min. preferably from two different sources of water supply shall be provided. The water reservoirs shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

HYDRANT SYSTEM :

1. The building shall be provided wet Riser of 100mm. Internal diameter pipe Line with single outlet landing valves at the staircase landings/half landings at the rate of one such riser for 1000 sq .m. of floor area. The system shall be so designed that shall be kept charged with water all the time under pressure and capable to discharge 1620Ltrs./min. at the ground floor level outlet and minimum 900 Lts./min. at the top most outlet. In both cases the running pressure shall not be less than 3.5 Kgs/cm². All other requirements shall conform I.S. 3844 – 1989.
2. Provision of Hose Reel in conjunction with wet Riser shall be made at each floor level conforming the relevant I.S. specification.
3. One number Fire Service Inlet shall be installed in front of the building in accordance with relevant I.S. specifications.

SPRINKLER INSTALLATION:

The automatic sprinkler installation shall be provided in entire Commercial area & Club Building as per I.S. 9972. Alarm Gong to be incorporated along with the sprinkler system.

FIRE PUMP:

1. One no. Jokey pump (electric) capacity 180 LPM,
2. One no. Main pump capacity 1620 LPM,
3. One no. Diesel driven Stand by pump of capacity 1620 LPM. And arranged in such a manner so that it will start automatically due to fall in pressure.

All the pumps shall be incorporated with both manual and auto starting facilities.

ELECTRICAL INSTALLATION AND DISTRIBUTION:

1. The electrical installation including Transformers, Switch Gear, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in I.S. specification.
2. The vertical and horizontal electrical ducts shall be sealed at each floor level by fire resisting materials.
3. The electrical installation shall be adequately protected with CO₂/D.C.P. Fire Extinguishers conforming



I.S. specification.

4. All electrical installation viz. Transformer, Switch Gear, LT/HT rooms shall be protected with both auto detection and suppression systems as per suitability.

5. For every 230V wiring above false ceiling 660 grade insulated cable shall be used Transformer Switch Gear H.T., L.T. and others electrical rooms shall be at the ground floor level the other electric rooms shall be at least 4 hrs. fire resisting capacity adequate ventilation arrangement shall have to be made in all the rooms, Dry and explosion proof type Transformer shall be installed.

Alternative Power Supply:

Arrangement for alternative power supply shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Deep Tube-Well Pump, Fire Alarm System etc. and also for illuminating the Staircase, Corridors, Lobbies etc. and other places of assembly of the building in case of normal power failure.

AUTO DETECTION AND ALARM SYSTEM:

1. Auto Fire Detection System with the help of Smoke Detectors shall be installed in all places of below and preferably above false ceiling of the building. The system shall also be made in place of rooms where valuable articles have been kept. The other requirements of the system shall be made in accordance with I.S. specification.

2. The suppression system shall be made with Fire Extinguishers particularly in Computer, Electrical processing and Data Room and in all rooms of irreplaceable articles.

3. Public Address System linked between all floors and Control Room shall have to be established.

4. All the installation shall also satisfy the I.S. Specification 2189 as amended and the code of practice as laid down in N.B.C. Part – IV.

AIR CONDITIONING SYSTEM (If any):

1. The A.H.U. shall be separated for each floor with the system. Air Ducts for individual floors.

2. Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System.

3. The system of auto shut down of A.H.U. shall be incorporated with the Auto Detection and Alarm System. The Air Handling Units room shall not be used for storage of any combustible First Aid Fire Fighting arrangement in the style of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

SMALL GEARS: IS : 903 -1993:-

Hose box , 15 M length Permolin delivery hose, Gun Metal short branch of half inch dia. One set at each half landing hydrant should be installed.

FIRST AID FIRE FIGHTING SYSTEM:

First Aid Fire Fighting arrangement in the style of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

GENERAL RECOMMENDATIONS:

1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.

2. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

3. Floor numbers and directional sign of escape route shall be displayed prominently.

4. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.

5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.

6. A crew of trained Fireman shall be maintained round the clock for safety of the building.

7. Mock Fire practice and Evacuation Drill shall be performed periodically with participation of all occupants of the building.

On compliance of all the above Life and Fire Safety Recommendation, the Director General, West Bengal Fire & Emergency Services shall be approved for necessary inspection and testing of all the installation, Fire Safety Certificate in favor of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B. : Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as



cancelled.

Memo No.: FSR/211862506300018316



**Director
West Bengal Fire & Emergency Services**

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in Unique Number : 211862506300018316