



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.: FSR/0125186221200321

Date : 25-09-2025

From :
Director
Fire Prevention Wing
West Bengal Fire & Emergency Services

To :
Mahendra Kumar Pandya and Others
Holding J.L. No.- 20, Mouza- Bhasa, District- South 24 Parganas, Pin- 743503, Under Paschim Bishnupur Gram Panchayat

Sub : Sub: Revised Fire Safety Recommendation for proposed construction of 104 Nos. (G+II) Storied Bungalows And Club at DAG NO. R.S. - 1511, 1529, 1534, 1537, 1510, 1509, 1531, 1532, 1530, 1512, 1507, 1508, 1502, 1651, 1650, 1500, 1533, 1535, 1538, 1540, 1541, 1551, 1345(P), 1501/1651, 1542(P), 1527, 1528, 1536, 1499; L.R. DAG NO.- 1560, 1578, 1586, 1559, 1558, 1580, 1581, 1579, 1561, 1556, 1557, 1550, 1549, 1548, 1546, 1582, 1583, 1584, 1586, 1587, 1589, 1590, 1600, 1371, 1591, 1576, 1577, 1585, 1545 & KHATIAN NO.- 4483, 4505, 4447, 4518, 4504, 4439, 4502, 4485, 4472, 4512, 4462, 4469, 4444, 4514, 4525, 4498, 4492, 4500, 4482, 4524, 4529, 4491, 4461, 4459, 4475, 4490, 4479, 4443, 4465, 4531, 4516, 4458, 4493, 4445, 4501, 4485, 4523, 4534, 4521, 4450, 4468, 4533, 4511, 5180, 5181, 5182, 5183, 4436, 4433, 4532, 4522, 4510, 4498, 4517, 4471, 4467, 4421, 4418, 4507, 4442, 4463, 4425, 4424, 4465, 4509, 4449, 4506, 4528, 4502, 4508, 4466, 4474, 4477, 4464, 4523, 4517, 4509, 4513, 4472, 4417, 4426, 4494, 4478, 4487, 4480, 4448 ; Holding J.L. No.- 20, Mouza- Bhasa, District- South 24 Parganas, P.S. - Bishnupur, P.O.- Bishnupur, Pin-743503, Under Paschim Bishnupur Gram Panchayat. .

This is in reference to your AIN 211882506300002145 dated 01-Sep-2025 regarding the Sub: Revised Fire Safety Recommendation for proposed construction of 104 Nos. (G+II) Storied Bungalows And Club at DAG NO. R.S. - 1511, 1529, 1534, 1537, 1510, 1509, 1531, 1532, 1530, 1512, 1507, 1508, 1502, 1651, 1650, 1500, 1533, 1535, 1538, 1540, 1541, 1551, 1345(P), 1501/1651, 1542(P), 1527, 1528, 1536, 1499; L.R. DAG NO.- 1560, 1578, 1586, 1559, 1558, 1580, 1581, 1579, 1561, 1556, 1557, 1550, 1549, 1548, 1546, 1582, 1583, 1584, 1586, 1587, 1589, 1590, 1600, 1371, 1591, 1576, 1577, 1585, 1545 & KHATIAN NO.- 4483, 4505, 4447, 4518, 4504, 4439, 4502, 4485, 4472, 4512, 4462, 4469, 4444, 4514, 4525, 4498, 4492, 4500, 4482, 4524, 4529, 4491, 4461, 4459, 4475, 4490, 4479, 4443, 4465, 4531, 4516, 4458, 4493, 4445, 4501, 4485, 4523, 4534, 4521, 4450, 4468, 4533, 4511, 5180, 5181, 5182, 5183, 4436, 4433, 4532, 4522, 4510, 4498, 4517, 4471, 4467, 4421, 4418, 4507, 4442, 4463, 4425, 4424, 4465, 4509, 4449, 4506, 4528, 4502, 4508, 4466, 4474, 4477, 4464, 4523, 4517, 4509, 4513, 4472, 4417, 4426, 4494, 4478, 4487, 4480, 4448, 4448 ; Holding J.L. No.- 20, Mouza- Bhasa, District- South 24 Parganas, P.S. - Bishnupur, P.O.- Bishnupur, Pin-743503, Under Paschim Bishnupur Gram Panchayat. .



The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the

Recommendation :

Fire Safety Recommendation which was issued from this department earlier vide memo no. FSR/0125186221200321, dated- 12.09.2022 , for proposed construction of 117 no's G+II storied under group Residential Building.(27 in part-A, 24 in part-B, 23in part -C,20 in part-D, 24 in part -E.) at Holding J.L. No.- 20, Mouza- Bhasa, District- South 24 Parganas, Pin- 743503, Under Paschim Bishnupur Gram Panchayat remain unchanged and strictly to be incorporated. With addition of automatic sprinkler shall have to be install in all floor area of G+II Assembly Building.

N.B: Any deviation and changes of the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this fire and life safety recommendation will be treated as cancelled.

Memo No.: FSR/0125186221200321



Director

West Bengal Fire and Emergency Services